



QUALITY CONTROL SUB DISTRICT LABORATORY KERALA WATER AUTHORITY

THALAYOLAPARAMBU, VAIKOM, KOTTAYAM

Telephone No. 04829-292143, Email: qcsdlvkm@gmail.com

(NABL Recognized Block level Government Drinking Water Testing Laboratory)

TEST REPORT

Certificate No. NABL - DWT - 00931

Report No:602/TPB/ 06/2025

Date: 24/06/2025

Customer Name & Address	1.Date of Receipt	13/06/2025
THE DIRECTOR RAJAGIRI AMALA CMI PUBLIC SCHOOL MOOTHEDATHUKAVU TV PURAM VAIKOM	2.Sampling done by	CUSTOMER
	3.Sample Code	2025/QC/TPB/T2861
	4.Source of Sample	TAP WATER
	5.Sample Quantity	2 LITRES
	6.Sample conditions	ACCEPTABLE
	7.Test performing dates :	13/06/2025 -19/06/2025

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500:2012	Limit of detection LOD	Result
1	Colour	HU	APHA 24 th Edition(2023) 2120 B - Visual comparison method	5	1	1
2	Odour		IS 3025 (part 5) -2018(Reaffirmed 2022)	Agreeable	Agreeable	Agreeable
3	Taste		IS 3025(part 8)-1984(Reaffirmed - 2023	Agreeable	Agreeable	Agreeable
4	Turbidity	(NTU)	IS 3025(part 10)-1984(Reaffirmed- 2023)- Nephelometric method	1	0.5	0.58
5	pH at 25 °C		IS 3025(part 11)- 2022- Potentiometric method	6.5 - 8.5	2	6.5
6	Alkalinity	(mg/litre)	IS 3025(part 23)-1986(Reaffirmed- 2023)- Indicator method	200	5	26.52
7	Total dissolved solids (TDS)	(mg/litre)	IS 3025(part 16)-1984(Reaffirmed- 2023)Gravimetric method/TDS Meter)	500	5	106.7
8	Total hardness (as CaCO ₃)	(mg/litre)	IS 3025(part 21)-2009 (Reaffirmed 2019)EDTA method	200	5	56
9	Calcium (as Ca)	(mg/litre)	IS 3025(part 40)-1991(Reaffirmed- 2023)EDTA Titrimetric method	75	5	10.42
10	Magnesium (as Mg)	(mg/litre)	APHA 24 th Edition(2023) 3500- Mg B Calculation method	30	5	7.29
11	Chloride (as Cl)	(mg/litre)	IS 3025(part 32)1988-(Reaffirmed 2019) Argentometric method	250	5	44.55

Remarks:-BDL

NB:- The result stated above related only to the sample(s)submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

- *Samples will be retained only for 7 days after completion of analysis
- *Sampling is not done by the Lab
- *BDL - Below Detection Limit
- *NT- Not Tested
- *End of the Report*

QUALITY CONTROL SUB DISTRICT LAB
KERALA WATER AUTHORITY
THALAYOLAPARAMBU, VAIKOM
KOTTAYAM 686605

Remya

Remya K.M

Reviewed and Authorized by
(Signature with Name)

QUALITY CONTROL SUB DISTRICT LAB
KERALA WATER AUTHORITY
THALAYOLAPARAMBU, VAIKOM, KOTTAYAM
Telephone No. 04829-292143, Email- qcsdlykkm@gmail.com

Test Report

Report No:602/TPB/06/2025	Date: 24/06/2025
---------------------------	------------------

Customer Name & Address THE DIRECTOR RAJAGIRI AMALA CMI PUBLIC SCHOOL MOOTHEDATHUKAVU TV PURAM VAIKOM	1.Date of Receipt	13/06/2025
	2.Sampling done by	CUSTOMER
	3.Sample Code	2025/QC/TPB/T2861
	4.Source of Sample	TAP WATER
	5.Sample Quantity	2 LITRES
	6.Sample Condition	ACCEPTABLE
	7.Test performing dates:	13/06/2025 - 19/06/2025

Sl. No	Characteristics	Unit	Test Method	Desirable limits as per IS 10500:2012	Result
1	Electrical conductivity at 25 °C	(Micromhos/cm)	IS 3025(part14)-2013 (Reaffirmed 2019)		164.6
2	Acidity	(mg/litre)	IS 3025(part22)-1986 (Reaffirmed 2019)Indicator Method		18
3	Sulphate (as SO ₄)	(mg/litre)	IS 3025(part24)-1986 (Reaffirmed 2022)Turbidity Method	200	BDL
4	Fluoride (as F)	(mg/litre)	KIT METHOD	1	BDL
5	Iron (as Fe)	(mg/litre)	IS 3025(part53)-2003 (Reaffirmed 2024) 1,10 Phenanthroline Method	1	0.13
6	Nitrate(as NO ₃)	(mg/litre)	KIT METHOD	45	BDL
7	Residual Chlorine	(mg/litre)	KIT METHOD	0.2	NIL

Remarks: -

NB:-The result stated above related only to the sample(s)submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

- *Samples will be retained only for 7 days after completion of analysis
- *Sampling is not done by the Lab
- *BDL – Below Detection Limit
- *NT- Not Tested

End of the Report

Reviewed and Authorized by
(Signature with Name)

QUALITY CONTROL SUB DISTRICT LAB
KERALA WATER AUTHORITY
THALAYOLAPARAMBU, VAIKOM
KOTTAYAM 686005

(Page 1/1)



QUALITY CONTROL SUB DISTRICT LAB
KERALA WATER AUTHORITY
THALAYOLAPARAMBU, VAIKOM, KOTTAYAM
Telephone No. 04829-292143, Email- qcsdlvkm@gmail.com

TEST REPORT

Report No: 602/TPB /06/2025	Date: 24/06/2025	
Customer Name & Address	1.Date of Receipt	13/06/2025
THE DIRECTOR RAJAGIRI AMALA CMI PUBLIC SCHOOL MOOTHEDATHUKAVU TV PURAM VAIKOM	2.Sampling done by	CUSTOMER
	3.Sample Code	2025/QC/TPB/T2861
	4.Source of Sample	TAP WATER
	5.Sample Quantity	100ml.
	6.Sample Condition	ACCEPTABLE
	7.Test performing dates:	13/06/2025 - 19/06/2025

BACTERIOLOGICAL ANALYSIS

Sl No.	Parameters	Acceptable limits as per – IS 10500-2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	IS 15185:2016	ABSENT
2	E-coli	Shall not be detected/100ml	IS 15185:2016	ABSENT

Test method

Coliforms: Membrane Filtration Method

E. coli: Membrane Filtration Method

Remarks:-

NB:- The result stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

*Samples will be retained only for 7 days after completion of analysis

*Sampling is not done by the Lab

END OF REPORT

QUALITY CONTROL SUB DISTRICT LAB
KERALA WATER AUTHORITY
THALAYOLAPARAMBU, VAIKOM
KOTTAYAM 686004

Authorized By
Page 1-1